



Sensepoint XCD SPECIFICATIONS

Flammable, toxic and oxygen gas detector for industrial applications

General Specifications												
Use	3 wire, 4-20mA and RS485 MODBUS output fixed point detector with in-built alarm and fault relays for the protection of personnel and plant from flammable, toxic and Oxygen hazards. Incorporating a transmitter with local display and fully configurable via non-intrusive magnetic switch interface.											
Electrical												
Input Voltage Range	16 to 32VDC (24VDC nominal)											
Max Power Consumption	Maximum power consumption is dependent on the type of gas sensor being used. Electrochemical cells = 3.7W, IR = 3.7W and catalytic = 4.9W. Maximum inrush current = 800mA at 24VDC											
Current Output	Sink or source											
Relays	3 x 5A@250VAC. Selectable normally open or normally closed (switch) and energized/de-energised (programmable) Alarm relays default normally open/de-energised. Fault relay default normally open/energized											
Communication	RS485, MODBUS RTU											
Construction												
Material	Housing: Epoxy painted aluminium alloy LM25 or 316 stainless steel Sensor: 316 stainless steel											
Weight (approx)	Aluminium Alloy LM25: 4.4lbs 316 Stainless Steel: 11lbs											
Mounting	Integral mounting plate with 4 x mounting holes suitable for M8 bolts. Optional pipe mounting kit for horizontal or vertical pipe Ø1.5 to 3" (2" nominal)											
Cable Entries	UL\cUL versions: 2 x ¾"NPT conduit entries. Suitable blanking plug supplied for use if only 1 entry used. Seal to maintain IP rating; ATEX/IECEx versions: 2 x M20 cable entries											
Environmental												
IP Rating	IP66 in accordance with EN60529:1992											
Certified Temperature Range	40°F to +149°F (-40°C to +65°C)											
Detectable Gases and XCD Sensor Performance												
Gas	User Selectable Full Scale Range	Default Range	Steps	User Selectable Cal Gas Range	Default Cal Point	Response Time (T90) Secs	Accuracy	Operating Temperature		Default Alarm Points		
								Min	Max	A1	A2	
Electrochemical Sensors												
Oxygen	25.0%Vol. only	25.0%Vol.	n/a	20.9%Vol. (Fixed)	20.9%Vol.	<30	<+/-0.5%Vol.	-20°C / -4°F	55°C / 131°F	19.5%Vol. ▼	23.5%Vol. ▲	
Hydrogen Sulfide	10.0 to 100.0ppm	50.0ppm	0.1ppm		25ppm	<50	<+/-1ppm	-20°C / -4°F	55°C / 131°F	10ppm ▲	20ppm ▲	
Carbon Monoxide	100 to 1,000ppm	300ppm	100ppm		100ppm	<30	<+/-6ppm	-20°C / -4°F	55°C / 131°F	30ppm ▲	100ppm ▲	
Hydrogen	1,000ppm only	1,000ppm	n/a		500ppm	<65	<+/-25ppm	-20°C / -4°F	55°C / 131°F	200ppm ▲	400ppm ▲	
Nitrogen Dioxide	10.0 to 50.0ppm	10.0ppm	5.0ppm		5.0ppm	<40	<+/-3ppm	-20°C / -4°F	55°C / 131°F	5.0ppm ▲	10.0ppm ▲	
Catalytic Bead Sensors												
Flammable 1 to 8	20.0 to 100.0%LEL	100%LEL	10%LEL	30 to 70% of selected full scale range	50%LEL	<25	<+/-1.5%LEL	-20°C / -4°F	55°C / 131°F	20%LEL ▲	40%LEL ▲	
Infrared Sensors												
Methane	20.0 to 100.0%LEL	100%LEL	10%LEL		50%LEL	<30	<+/-1.5%LEL	-20°C / -4°F	50°C / 122°F	20%LEL ▲	40%LEL ▲	
Propane	20.0 to 100.0%LEL	100%LEL	10%LEL	50%LEL	<30	<+/-1.5%LEL	-20°C / -4°F	50°C / 122°F	20%LEL ▲	40%LEL ▲		
Carbon Dioxide	2%Vol. only	2%Vol.	n/a	1%Vol.	<30	<+/-0.04%Vol.	-20°C / -4°F	50°C / 122°F	0.4%Vol. ▲	0.8%Vol. ▲		
▲ - Rising Alarm ▼ - Falling Alarm												
Certification												
US, Latin America, Canada	UL/c-UL - Class I, Division 1, Groups B, C and D, Class I, Division 2, Groups B, C & D, Class II, Division 1, Groups E, F & G, Class II, Division 2, Groups F & G. -40°C to +65°C											
European	ATEX Ex II 2 GD Ex d IIC Gb T6 (Ta -40°C to +65°C) Ex tb IIIC T85°C Db IP66											
International	IEC Ex d IIC Gb T6 (Ta -40°C to +65°C) Ex tb IIIC T85°C Db IP66											
EMC	CE: EN50270:2006 EN6100-6-4:2007											
Performance	UL508; CSA 22.2 No. 152 (flammable gasses, excludes infrared sensors); ATEX, IEC/EN60079-29-1:2007, EN45544, EN50104, EN50271; China: PA Pattern Measurement (for transmitter and toxic gas sensors) "CCCF" Shenyang for Flammable (fire dept approval)											

Find out more

www.honeywellanalytics.com

Toll-free: 800.538.0363

Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.